



COVER REMOVED
IN FRONT VIEW

NOTE: AGENCY CRITICAL DRAWING.
NO MODIFICATIONS ALLOWED WITHOUT
REFERENCE TO APPROVAL AGENCIES.

121	200 TO 425	95 TO 215
120	0 TO 225	-17.7 TO 105
MODEL	F	C
ND.	ADJUSTABLE RANGE	

CE COMPLIANT TO
APPLICABLE DIRECTIVE(S)

0539 ATEX APPROVED
II 2 G/D EEx d IIC T6
-40°C ≤ Tamb. ≤ +71°C
IP66

I & M SHEET IMT120

APPROVALS:
UL LISTED
CLASS I, DIVISIONS 1 & 2,
GROUPS B, C & D
CLASS II, DIVISIONS 1 & 2,
GROUPS E, F & G
CLASS III
-50°C ≤ Tamb. ≤ +71°C
CLASS I, ZONE 1, GROUP IIB + H₂ T6
ENCLOSURE TYPE 4X, 7, 9

UL US

SYM	DESCRIPTION	DATE	DWN	APPD
V	UPDATED ENCLOSURE. EGN#E4345.	2-17-12	RCI	SJM
U	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. EGN#E0368	6-16-03	S.R.	LK
T	ADDED CENELEC & CE APPROVALS. EGN#E0009	8-27-02	S.R.	LK
S	UPDATED ENCLOSURE & COVER. EGN#C9734	2/27/02	S.R.	LK
R	REDRAWN PER NEW ENCLOSURE DESIGN. EGN#C5438	3-20-96	S.R.	JJM

REVISIONS	DESCRIPTION	DATE	DWN	APPD

ORIGINAL DATE 7-29-86	TITLE	DF 001
DRWN PETER WEILLER	B121-	REV. C
CHKD N.MOCKAY JR.	120 & 121	
APPD A. MINASSIAN		
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES		
DO NOT SCALE THIS DRAWING	SCALE 1:2	DWG NO A-12128
UNITED ELECTRIC CONTROLS COMPANY WATERTOWN * MASSACHUSETTS		